



HPi Verification Services

Type Examination Certificate

This is to certify that the product listed below conforms to the requirements of the

Pressure Equipment Directive

97/23/EC Annex III Module B

Certificate Number	HPIVS/P1002-112-I-01 rev. 1	Date of Expiry	01-Jun-2025
Date of Issue	22-Nov-2018		

Designer

[Blurred text]

THIS SECTION HAS BEEN BLURRED FOR CONFIDENTIAL REASONS.

Description of Pressure Equipment

[Blurred text]

Cylinder material: Q/BQB 403-2009 DC06

Drawing No

JE-50-C-00; JE-100-C-00; JE-150-C-00, JE-300-C-00;

Serial No

Not applicable

Design Pressure

PS: 12 bar (min burst tests 120 bar)

Design Temperature

-20 to 60 °C

Standards Used

BS 6165, EN 3-7, EN 3-8, EN 3-10, Q/JR 007-2013

Report Reference

P1002-112-1 and P1002-112-DR01

This Certificate is valid in any European Economic Area Member State.

This Certificate has been issued by HPi Verification Services Ltd which is a body notified to the European Commission according to the provisions of the Pressure Equipment Directive (Notified Body number 1521).

This Certificate is issued following the assessment of a representative sample of the Pressure Equipment detailed above in accordance with the provisions of the above regulations. The equipment must be subject to an appropriate conformity assessment module during manufacture prior to the CE Mark being affixed.

Check this certificate is genuine



Managing Director

Technical Director



EU Notified Body No. 1521
Company registered in England #7217086

© HPi Verification Services Ltd. 2018

Tel +44 1491 822818
Fax +44 700 600 6831
Email enquiries@eucertification.com
www.eucertification.com

HPi Verification Services Ltd.
The Manor House
Howbery Park, Wallingford
OX10 8BA, United Kingdom