

TYPE APPROVAL CERTIFICATENo. **FPE255612CS/001**Enclosure - Page 1 of 1
[REDACTED]**Product description**

Fire extinguishing device 8B - C

Material of case	Fireproofing ABS
Maximum external diameter	53 mm
Inner cylinder thickness	0.8 mm
Number of extinguishing charges	1 cylinder, steel ST16
Total weight	500 gr ± 10g
Total length	242 mm
Extinguishing agent	Potassium aerosol
Fire class	8B - C

Field of application

Fire extinguishing device for pleasure yacht - Flame inhibitor with aerosol to be used as additional device for the extinguishing of fire of flammable liquid or gas.

Reference document

Extinguishing device [REDACTED] - User Manual approved by RINA with n° CSST 9203.

General Assembly drawing [REDACTED] and approved by RINA with n° CSST 9206.

[REDACTED] and filed by RINA with n° CSST 9200.

Test report

Testing report n° Zb201210019 dated 25/06/2012 issued by National Center for quality Supervision and Test of Fire Fighting Equipment, filed by RINA with n° CSST 9209.

Remarks

Mass produced articles are to be marked or labelled with the trade name and the data of the Company to whom this Certificate is addressed. The validity of this Certificate is dependent on the compliance of each manufactured product with the prototype which underwent the approval tests and such compliance shall be stated by the manufacturer. Moreover, the Company is fully responsible for ensuring compliance by performing all the necessary checks also in respect of its sub-suppliers. Notwithstanding the above, RINA reserves the right to make any checks it deems appropriate during production. The validity of this Certificate ceases in the case of amendments to the rules on the basis of which the Certificate was issued.

Genoa October 15, 2012

RINA
Via Corsica, 12 - 16128 Genova
Tel +39 010 53851
Fax +39 010 5351000

[Handwritten signature]

